

-----Original Message-----

From: Ohl.Matthew@epamail.epa.gov [mailto:Ohl.Matthew@epamail.epa.gov]

Sent: Monday, April 18, 2011 10:15 AM

To: DSullivan@NiSource.com; Val Blumenfeld; lisa.bradley@aecom.com

Cc: Thurlow.Timothy@epamail.epa.gov

Subject: Town of Pines

Good morning:

I understand from Town of Pines Building Commissioner, Allen Murray that the culvert at the edge of Ardendale Rd. about twenty ft. north of the intersection of US Highway 20 and Ardendale Rd. has been causing a hole to open at the edge of the road. Mr. Murray stated that the Town of Pines has had to fill the hole previously and recently excavated the location finding that a section of 4 ft. metal culvert was removed during the municipal water service extension and replaced with a 3 ft. plastic culvert was sleeved into the remaining metal culvert. Mr. Murray stated his understanding of the settlement agreement is that existing utilities, roads, etc. would be restored to their original condition and not replaced with lesser materials. Please advise what action you are prepared to take in response to this issue.

Thank you.

Matthew J. Ohl

Remedial Project Manager

United States Environmental Protection Agency

77 West Jackson Boulevard, SR-6J

Chicago, IL 60604-3590

phone: 312.886.4442

fax: 312.692.2447

e-mail: ohl.matthew@epa.gov